

OIL INDIA LIMITED
(A Government of India Enterprise)
P.O. Duliajan – 786602, Assam, India
Website: www.oil-india.com

Corrigendum No. 2 to IFB No. SDG7383P18

Engineering, Fabrication and supply of Modular Packages Contract (MPC) for OCS at Nadua and GGS at East Khagorijan in Dibrugarh District, Assam

1. This Corrigendum is issued to notify the following:

a) Various OIL/ Consultant's responses to bidder's queries which were earlier marked for review in the existing **Annexure- 2 to Corrigendum No. 1** are now amended. All the bidders are requested to refer to **Annexure- I** attached herewith.

b) Revised specification for insulation under **SL No. 41 of Annexure – 2 to corrigendum No. 1** is attached separately in **“technical attachment tab”** in E-tender portal.

c) Detailed heat and mass balance sheets under **SL No. 44 of Annexure – 2 to corrigendum No. 1** are attached separately in **“technical attachment tab”** in E-tender portal. Bidders to make conscience of the same while submitting their final bids.

d) Extension of the Bid Closing/Technical Bid Opening date and date of sale of bid document as under :-

i) Bid Closing Date & Time : 16.05.2018, 11:00 hrs. IST.

ii) Technical Bid Opening Date & Time : 16.05.2018, 14:00 hrs. IST.

iii) Last Date & Time of Sale of Bid : 09.05.2018, 15:30 hrs. IST.

Document

2. All other terms and conditions of the tender remain unaltered.

3. All the prospective bidders are requested to regularly visit OIL's website: www.oil-india.com and e-procurement portal <https://etender.srm.oilindia.in/irj/portal> for further announcements/latest information related to this tender.

.....

Annexure – I to Corrigendum No. 2

A. Following are amended OIL/Consultant’s responses to pre-bid queries issued vide Corrigendum No. 1 to IFB No. SDG7383P18:

Clause No. of Annexure- 2 to Corrigendum No. 1	Existing OIL/Consultant’s response	Amended to be read as
SL. No. 8	Bidders query is being reviewed.	Delivery date extension is not acceptable on account of document approval cycle. Documents will be approved within the specified time frame.
SL. No. 9	Cannot.	Tender conditions prevail.
SL. No 14	Bidders query is being reviewed.	Time extension is not possible.
SL. No 15	Bidders query is being reviewed.	Bid submission date has been extended upto 16.05.2018
SL. No 17	OIL doesn’t maintain an approved vendor list. Please refer vendor selection criteria in the tender for choosing vendors.	There is no approved vendor list. Bidder to follow equipment qualification criteria.
SL. No 25	Bidders query is being reviewed.	Bid submission date has been extended upto 16.05.2018
SL. No 30	Third party inspection is in the scope of EPCM	Refer Instruction to Bidders and General Terms and Conditions - Refer Clause 42; Terms of Reference & Technical Specifications- Refer clause 14
SL. No 31	EPCM will bear the expenses for the presence of third party inspector	Refer Instruction to Bidders and General Terms and Conditions - Refer Clause 42; Terms of Reference & Technical Specifications- Refer clause 14
SL. No 32	Contractor understanding isn’t correct. Material handling requirement for equipment maintenance within the package is in contractor scope. Unloading of material at the site	For maintenance of all the equipment within the package / module, contractor shall install suitable material handling equipments as necessary.

	will be done by others.	
SL. No 33	Deluge system comprising of deluge piping with spray nozzles and instrument air piping with Quartzoid Bulb (QB) detectors and automatic deluge valves is in the MPC2 contractor's scope and shall be shipped as integral part of the package.	Deluge System within the packages shall be provided by the Contractor
SL. No 34	Fire extinguisher shall be loosely supplied and further it shall be installed at the site by the MPC-2 contractor	MPC-2 Contractor shall supply & install fire extinguisher for their package.
SL. No 35	Contractor proposal isn't accepted	F&G detectors supply and installation are in contractor's scope
SL. No 36	Confirmed. Special tools and tackles shall also be included in the base scope.	Contractor understanding is correct.
SL. No 38	Contractors shall include consumable also in their base commercial offer.	Consumables required for Pre-Commissioning and Commissioning shall be included in MPC-2 Contractor scope. Also one month additional consumables required for PGTR will be in MPC-2 contractor scope.
SL. No 39	MPC contractor shall provide six (6) sets of final approved documents and laminated drawings and 3 sets of soft copies (2 copies in CD-ROM and one copy in Flash Drive) of all the Final/ As-Built document listed in the minimum document requirement	5 hard copies shall be submitted for final documentation. However, contractor to submit soft copy with native file for applicable documents of all revisions for consultant's review and approval.

	list.	
SL. No 40	HAZOP and Fire and Gas mapping are in contractor responsibility.	OIL/Consultant will provide Basic Engineering stage HAZOP, HAZID, QRA and SIL reports. MPC-2 Contractor shall carry out HAZOP, SIL study for the detailed package engineering stage
SL. No 41	Tender requirements prevail.	Attached separately under “technical attachment tab” in E-tender portal.
SL. No 43	Scope split is clearly mentioned in the tender. Any specific queries can be clarified	MPC-2 Contractors Scope is clearly defined in P&IDs issued.
SL. No 44	Will not be provided.	Attached separately under “technical attachment tab” in E-tender portal.
SL. No 46	Closed drain system is part of MPC-2. Please refer P&ID 17039-EK-P-DW-0216-02, Rev B the closed drain system within the skid is indicated as MPC2 scope only.	Closed drain system is part of MPC-2 Contractor scope.
SL. No 48	No approved vendor list and countries are available. However the contractor to select prospective vendors who meets the eligibility criteria specified in the tender. Contractor to submit the sub vendor list and credentials along with the offer for the EPCM/OIL approval.	This clause stands deleted
SL. No 50	Bidders query is being reviewed.	Bid submission date has been extended upto 16.05.2018

B. Following is summary of OIL/Consultant's responses to additional pre-bid queries raised by bidders after issuance of Corrigendum No. 1 to IFB No. SDG7383P18:

SL. No.	REFERENCE DOCUMENT & TITLE	DESCRIPTION	BIDDER QUERIES	OIL / CONSULTANT's Responses
1	General	Scope split	Please define the scope of interconnecting piping and E&I bulk between skids are within MPC contractors or others. The Bid document states that the piping, cable tray and etc. tie-in shall be terminated at the package edge. Is the package edge defined as skid edge?	The interconnecting Piping & E&I bulk within the package is in MPC-2 contractor scope. Outside Package interconnecting Piping & E&I bulk will be in Others scope. For package boundaries refer plot plan.
2	Process	Flare	Please advise if the entire enclosed ground flare is by MPC-2 or just the flare tip shipped loose?	Entire enclosed ground flare is in contractor's scope. Flare header and associated piping related to flare package will be provided at battery limit by others. Flare package includes but not limited to Flare KOD, Ultrasonic flow meter, Combustion chamber (Stack, Exterior Frame, Refractory Lining), Crushed rocks/Gravel (If applicable), Burners, Piping systems, Wind fence, Operational and safety controls. Civil work related to flare system will be designed by MPC - 2 contractors and constructed by others.
