



CORRIGENDUM

ADDENDUM No. 01 dated 24.10.2020

To

TENDER NO. SDH5421P21/09

This addendum is issued to include the following additional specifications:

Existing Clause ref.	Existing clause	Additional clause
Annexure-A, Part: AA, Item no. 10, (Item details)	Additional information	L) Required material of construction for 200 Ltr. TANK: SS 304 – ASTM 240 M) Temperature of Natural Gas: 15 deg C to 45 deg C N) Flow rate of Natural Gas: Available Gas Inlet pr.: 5.5 kg/cm², Flow rate: 9350 m³/d. O) Gas Composition: Methane 90.63, Ethane 4.546, Propane 1.35, i-Butane 0.24, n-Butane 0.32, i-Pentane 0.12, n-Pentane 0.10, Hexane +0.17, GCV 9520.1, NCV 8594.9.

All other terms & conditions of the bid document remain unaltered.

sd/-
Amrit Loushon Bora
Sr. Manager Materials(FD)
For CGM-Materials(HoD)
For Resident Chief Executive