

Corrigendum No. 3 dated 27.01.2023.

to

Tender No. CDI2352P23

for

Hiring Services for Design, Engineering, Procurement, Fabrication, Supply, Construction, Installation and Commissioning of Pontoon Type Raw Water intake Plant including cross country Raw Water Pipeline, Plant Piping and all Electrical and Instrumentation jobs on EPC-LSTK Basis at Oil India Limited, Duliajan, Assam.

This Corrigendum is issued to notify that:

1.0 Shell Thickness/Class (mm) of Raw water pipeline is to be read as **18 mm** in Point No. 7 of table under Clause No. E (II)14(I) and Point 5 of table under Clause No. E(II)14(II) of Section-III Scope of Work – Mechanical Engineering and Plant Piping [Page No. 13 of 14], instead of the existing.

2.0 All other terms and conditions of the Bid Document (including any corrigendum issued thereof) remain unchanged. Details can be viewed at www.oil-india.com.

SM-Contracts(S)